

BATAVIA PUBLIC SCHOOL DISTRICT 101
BHS Tennis Court Repairs and Color Coating
GENERAL BID SPECIFICATIONS
6/6/2016 (Addendum #1)

The follow items shall be included as part of the general bid specifications published on 5/27/2016. They are provided to increase clarity of the intended scope of work and to answer any questions asked by contractors reviewing the bid documents.

1. In appendix D, please add the following sections:
 - a. Fence post footing patching.
 - i. Remove loose concrete and thoroughly clean exposed footings and surrounding area
 - ii. Treat vegetation
 - iii. Remove or loosen Chain link and rails as needed to provide room to compact asphalt. Properly resecure upon completion.
 - iv. Prime exposed concrete and asphalt where new asphalt will be installed with SS-1 asphalt primer
 - v. Install surface mix HMA and properly compact to result in a new surface level with adjacent asphalt surface.
 - vi. ***NO FUEL TO BE USED DURING ASPHALT INSTALL. Detergent water only.
 - vii. Pre coat new asphalt with acrylic resurfacer as needed so patching will not be noticeable upon completion of the color coat system.
 - b. Warranty
 - i. Color System shall come with a minimum 3 year warranty.
2. Currently the color coat system does not extend beyond the fence. This bid will not require that the contractor coat outside the fence during this resurfacing. All (8) tennis courts shall be included in the scope of work.
3. Bid Bond was request to be \$50,000. This amount has been revised to 10% of the Base Bid amount.
4. As alternate#1 to the base bid, the District would like a proposal to replace the Net Posts & Footings. The existing footings are 12" round footings extending 42" deep. They shall be removed and replaced with bell footing as detailed below. The alternate number may be simply penciled in under the base bid number of the Bid Form found in Appendix E.

